

79D13/KBC

J.A. Lyons Esq.,
N.H.B.C.,
24 King Street,
Saffron Walden,
Essex.

12th November, 1979.

Dear Sir,

re: 5 Houses at rear of Bowden Lane, High Wycombe

Following an inspection of the site today, we would like to confirm that at present the excavation for the foundations is being taken approximately 300 m.m. below the underside of unsuitable material. This material appears capable of sustaining the ground bearing pressure for which the foundations have been designed for.

Yours faithfully,

K.B. Cox